



NOTIFIED BODY No. 1488
INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT

ul. FILTROWA 1, 00-611 WARSZAWA
tel.: + 48 (22) 57 96 167, + 48 (22) 57 96 168
e-mail: certyfikacja@itb.pl, www.itb.pl



CERTIFICATE OF CONSTANCY OF PERFORMANCE
1488-CPR-0810/W

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

External, hinged, fire resisting or fire resisting and smoke control doors of ALUPROF® MB-78EI system with over panels and/or side panels

general identification, intended use and performance of the product are described in the Annex No. Z-1488-CPR-0810/W which is an integral part of this certificate

placed on the market under the name or trade mark of:

Przedsiębiorstwo Produkcyjno - Usługowe PLASTIMET Sp. z o.o.
ul. Suwalska 82
19-300 Ełk
Poland

and produced in the manufacturing plant:

Przedsiębiorstwo Produkcyjno - Usługowe PLASTIMET Sp. z o.o.
Niedźwiedzkie 1B
19-335 Prostki
Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 16034:2014

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 23.01.2020 (updated on 27.07.2023) and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 27.07.2023

Annex No. Z-1488-CPR-0810/W, page 1/4
which is an integral part of the certificate No. 1488-CPR-0810/W

External, hinged, fire resisting or fire resisting and smoke control doors of ALUPROF® MB-78EI system with over panels and/or side panels

Essential characteristics of the product ¹⁾	Harmonized standard	Mandates levels and/or classes
	EN 16034:2014	
Resistance to fire	4.1	El ₂ 30 / EW 30 / E 30
		El ₂ 60 / EW 60 / E 60
		El ₂ 90 / EW 90 / E 90
Smoke control	4.2	S _a , S ₂₀₀
Ability to release	4.3	NPD
Self-closing	4.4	C
Durability of ability to release	4.5.1	NPD
Durability of self closing - against degradation (cycling testing) - against ageing (corrosion)	4.5.2.1	5 (200 000 cycles) NPD
	4.5.2.2	

Declared intended use of the product:

External, hinged, aluminium doors of ALUPROF® MB-78EI system, optionally equipped with over panels and / or side panels – contained within a single perimeter frame for inclusion in a single aperture – in the following versions:

- ✓ MB-78EI EI30 – with the declared fire resistance class: El₂ 30 / EW 30 / E 30
- ✓ MB-78EI EI30 – with the declared fire resistance and smoke-control class: El₂ 30 / EW 30 / E 30 / S_a, S₂₀₀
- ✓ MB-78EI EI30 – with the declared fire resistance, smoke-control and self-closing class: El₂ 30 / EW 30 / E 30 / S_a, S₂₀₀ / C5
- ✓ MB-78EI EI30 – with the declared fire resistance and self-closing class: El₂ 30 / EW 30 / E 30 / C5

- ✓ MB-78EI EI60 – with the declared fire resistance class: El₂ 60 / EW 60 / E 60
- ✓ MB-78EI EI60 – with the declared fire resistance and smoke-control class: El₂ 60 / EW 60 / E 60 / S_a, S₂₀₀
- ✓ MB-78EI EI60 – with the declared fire resistance, smoke-control and self-closing class: El₂ 60 / EW 60 / E 60 / S_a, S₂₀₀ / C5
- ✓ MB-78EI EI60 – with the declared fire resistance and self-closing class: El₂ 60 / EW 60 / E 60 / C5

- ✓ MB-78EI EI90 – with the declared fire resistance class: El₂ 90 / EW 90 / E 90
- ✓ MB-78EI EI90 – with the declared fire resistance and smoke-control class: El₂ 90 / EW 90 / E 90 / S_a, S₂₀₀
- ✓ MB-78EI EI90 – with the declared fire resistance, smoke-control and self-closing class: El₂ 90 / EW 90 / E 90 / S_a, S₂₀₀ / C5
- ✓ MB-78EI EI90 – with the declared fire resistance and self-closing class: El₂ 90 / EW 90 / E 90 / C5

are intended for use in areas in the reach of persons, in residential, public and industrial buildings, in fire- and smoke compartmentation.

¹⁾ **Note:** The standard EN 16034:2014 shall be applied together with the standard EN 14351-1:2006+A2:2016.

Regardless of the essential characteristics listed in this certificate, the manufacturer shall declare the performance of the essential characteristics covered by the standard EN 14351-1:2006+A2:2016 that are not covered by the scope of the tasks of the notified certification body and this certificate.

HEAD
of the Certification Department



Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej



Anna Panek, M.Sc. Eng.

Warsaw, 27.07.2023

Annex No. Z-1488-CPR-0810/W, page 2/4
which is an integral part of the certificate No. 1488-CPR-0810/W

External, hinged, fire resisting or fire resisting and smoke control doors of ALUPROF® MB-78EI system with over panels and/or side panels

General identification of the product ¹⁾:

Table No. 1. Doors of the ALUPROF® MB-78EI system - version **MB-78EI EI30** - optionally equipped with over panels and/or side panels - within one common structural frame.

Declared essential characteristics, acc. to PN-EN 16034:2014-11	Resistance to fire	Resistance to fire Smoke control	Resistance to fire Smoke control Self-closing	Resistance to fire Self-closing	
Classification acc. to PN-EN 13501-2:2016-07	EI ₂ 30/ EW 30/ E 30	EI ₂ 30/ EW 30/ E 30/ S _a , S ₂₀₀	EI ₂ 30/ EW 30/ E 30/ S _a , S ₂₀₀ / C5	EI ₂ 30/ EW 30/ E 30/ C5	
Construction features	Aluminium, profile, single- and double-leaf, hinged doors, with transparent and/or opaque infills of door leaves as well as side and over panels; profiles of leaf and frame - aluminium profiles of the MB-78EI system with a thermal barrier; depth of structural profiles - 78 mm				
Transparent infills ²⁾	Applies to: door leaves and side-and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 3.3 of classification report No. 1036.4/20/R499NZZP, ed. 4	Applies to: door leaves and side-and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 4.3 of classification report No. 1036.4/20/R499NZZP, ed. 4	Applies to: door leaves and side-and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 5.3 of classification report No. 1036.4/20/R499NZZP, ed. 4	Applies to: door leaves and side-and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 6.3 of classification report No. 1036.4/20/R499NZZP, ed. 4	
Opaque infills ²⁾	Applies to: door leaves and side-and over panels. Opaque infills according to the description in points: 3.4, 3.5 of classification report No. 1036.4/20/R499NZZP, ed. 4	Applies to: door leaves and side-and over panels. Opaque infills according to the description in points: 4.4, 4.5 of classification report No. 1036.4/20/R499NZZP, ed. 4	Applies to: door leaves and side-and over panels. Opaque infills according to the description in points: 5.4, 5.5 of classification report No. 1036.4/20/R499NZZP, ed. 4	Applies to: door leaves and side-and over panels. Opaque infills according to the description in points: 6.4, 6.5 of classification report No. 1036.4/20/R499NZZP, ed. 4	
Fittings	Assortment of fittings, as described in point 3.6 of classification report No. 1036.4/20/R499NZZP, ed. 4	Assortment of fittings, as described in point 4.6 of classification report No. 1036.4/20/R499NZZP, ed. 4	Assortment of fittings, as described in point 5.6 of classification report No. 1036.4/20/R499NZZP, ed. 4	Assortment of fittings, as described in point 6.6 of classification report No. 1036.4/20/R499NZZP, ed. 4	
Dimensions ³⁾	External dimensions of a door leaf (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm]	(392 ÷ 1400) x (392 ÷ 3006)	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1400) x (392 ÷ 3006)
	Max. total width of two leaves of double-leaf door, [mm]	2500	2500	2500	2500
	Maximum door height including over panel, [mm]	3800	3225	3225	3800
	Max. external dim. of the over panels (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm] - in relations to their permissible surface area [m ²]	(372 ÷ 2800) x (372 ÷ 1300) 0,14 ÷ 3,64	(372 ÷ 2384) x (372 ÷ 1300) 0,14 ÷ 3,10 or (372 ÷ 2800) x (372 ÷ 765) 0,14 ÷ 2,14	(372 ÷ 2384) x (372 ÷ 1300) 0,14 ÷ 3,10 or (372 ÷ 2800) x (372 ÷ 765) 0,14 ÷ 2,14	(372 ÷ 2800) x (372 ÷ 1300) 0,14 ÷ 3,64
	Max. external dimensions of the side panels (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm] - in relations to their permissible surface area, [m ²]	(372 ÷ 1600) x (372 ÷ 2200) 0,14 ÷ 3,52 or (372 ÷ 1330) x (372 ÷ 2576) 0,14 ÷ 3,42	(372 ÷ 1362) x (372 ÷ 2300) 0,14 ÷ 3,13 or (372 ÷ 681) x (372 ÷ 2576) 0,14 ÷ 1,75	(372 ÷ 1362) x (372 ÷ 2300) 0,14 ÷ 3,13 or (372 ÷ 681) x (372 ÷ 2576) 0,14 ÷ 1,75	(372 ÷ 1600) x (372 ÷ 2200) 0,14 ÷ 3,52 or (372 ÷ 1330) x (372 ÷ 2576) 0,14 ÷ 3,42
	Permissible leaf surface area of single-leaf door [m ²]	0,15 ÷ 4,06	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 4,06
	Permissible leaf surface area for double-leaf doors, [m ²]	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50

¹⁾ The detailed technical identification, scope and conditions of use of the doors ALUPROF® MB-78EI system – version MB-78EI EI30 covered by this certificate No. 1488-CPR-0810/W, are included in the classification report No.: 1036.4/20/R499NZZP, ed. 4

²⁾ The selection of transparent and opaque infills should take into account the requirements of national regulations in individual EU member countries regarding the levels of performance related to the essential characteristics covered by EN 14351-1:2006+A2:2016 (among others, this applies to the heat transfer coefficient), which are not covered by the scope of tasks of the notified certification body and this certificate.

³⁾ When selecting dimensions, the requirements of national regulations in individual EU member countries should be taken into account.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Annex No. Z-1488-CPR-0810/W, page 3/4
which is an integral part of the certificate No. 1488-CPR-0810/W

External, hinged, fire resisting or fire resisting and smoke control doors of ALUPROF® MB-78EI system with over panels and/or side panels

General identification of the product ¹⁾:

Table No. 2. Doors of the ALUPROF® MB-78EI system - version **MB-78EI EI60** - optionally equipped with over panels and/or side panels - within one common structural frame.

Declared essential characteristics, acc. to PN-EN 16034:2014-11	Resistance to fire	Resistance to fire Smoke control	Resistance to fire Smoke control Self-closing	Resistance to fire Self-closing	
Classification acc. to PN-EN 13501-2:2016-07	EI ₂ 60/ EW 60/ E 30	EI ₂ 60/ EW 60/ E 60/ S _a , S ₂₀₀	EI ₂ 60/ EW 60/ E 60/ S _a , S ₂₀₀ / C5	EI ₂ 60/ EW 60/ E 60/ C5	
Construction features	Aluminium, profile, single- and double-leaf, hinged doors, with transparent and/or opaque infills of door leaves as well as side- and over panels; depth of structural profiles - 78 mm				
Transparent infills ²⁾	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 3.3 of classification report No. 1036.5/20/R499NZZP, ed. 4	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 4.3 of classification report No. 1036.5/20/R499NZZP, ed. 4	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 5.3 of classification report No. 1036.5/20/R499NZZP, ed. 4	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber/double-chamber insulating glass units, as described in point 6.3 of classification report No. 1036.5/20/R499NZZP, ed. 4	
Opaque infills ²⁾	Applies to: door leaves and side- and over panels. Opaque infills, according to the description in points: 3.4, 3.5 of classification report No. 1036.5/20/R499NZZP, ed. 4	Applies to: door leaves and side- and over panels. Opaque infills, according to the description in points: 4.4, 4.5 of classification report No. 1036.5/20/R499NZZP, ed. 4	Applies to: door leaves and side- and over panels. Opaque infills, according to the description in points: 5.4, 5.5 of classification report No. 1036.5/20/R499NZZP, ed. 4	Applies to: door leaves and side- and over panels. Opaque infills, according to the description in points: 6.4, 6.5 of classification report No. 1036.5/20/R499NZZP, ed. 4	
Fittings	Assortment of fittings, as described in point 3.6 of classification report No. 1036.5/20/R499NZZP, ed. 4	Assortment of fittings, as described in point 4.6 of classification report No. 1036.5/20/R499NZZP, ed. 4	Assortment of fittings, as described in point 5.6 of classification report No. 1036.5/20/R499NZZP, ed. 4	Assortment of fittings, as described in point 6.6 of classification report No. 1036.5/20/R499NZZP, ed. 4	
Dimensions ³⁾	External dimensions of a door leaf (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm]	(392 ÷ 1500) x (392 ÷ 3006)	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1500) x (392 ÷ 3006)
	Max. total width of two leaves of double-leaf door, [mm]	2984	2500	2500	2500
	Maximum door height including over panel, [mm]	3800	3225	3225	3800
	Max. external dim. of the over panels (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm] - in relations to their permissible surface area [m ²]	(372 ÷ 2800) x (372 ÷ 1300) 0,14 ÷ 3,64	(372 ÷ 2384) x (372 ÷ 1300) 0,14 ÷ 3,10 or (372 ÷ 2800) x (372 ÷ 765) 0,14 ÷ 2,14	(372 ÷ 2384) x (372 ÷ 1300) 0,14 ÷ 3,10 or (372 ÷ 2800) x (372 ÷ 765) 0,14 ÷ 2,14	(372 ÷ 2800) x (372 ÷ 1300) 0,14 ÷ 3,64
	Max. external dimensions of the side panels (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm] - in relations to their permissible surface area, [m ²]	(372 ÷ 1600) x (372 ÷ 2200) 0,14 ÷ 3,52 or (372 ÷ 1000) x (372 ÷ 2576) 0,14 ÷ 2,60	(372 ÷ 1362) x (372 ÷ 2300) 0,14 ÷ 3,13 or (372 ÷ 681) x (372 ÷ 2576) 0,14 ÷ 1,75	(372 ÷ 1362) x (372 ÷ 2300) 0,14 ÷ 3,13 or (372 ÷ 681) x (372 ÷ 2576) 0,14 ÷ 1,75	(372 ÷ 1600) x (372 ÷ 2200) 0,14 ÷ 3,52 or (372 ÷ 1000) x (372 ÷ 2576) 0,14 ÷ 2,60
	Permissible leaf surface area of single-leaf door [m ²]	0,15 ÷ 4,06	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 4,06
Permissible leaf surface area for double-leaf doors, [m ²]	0,15 ÷ 3,75	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50	

¹⁾ The detailed technical identification, scope and conditions of use of the doors ALUPROF® MB-78EI system – version MB-78EI EI60 covered by this certificate No. 1488-CPR-0810/W, are included in the classification report No.: 1036.5/20/R499NZZP, ed. 4

²⁾ The selection of transparent and opaque infills should take into account the requirements of national regulations in individual EU member countries regarding the levels of performance related to the essential characteristics covered by EN 14351-1:2006+A2:2016 (among others, this applies to the heat transfer coefficient), which are not covered by the scope of tasks of the notified certification body and this certificate.

³⁾ When selecting dimensions, the requirements of national regulations in individual EU member countries should be taken into account.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 27.07.2023

Annex No. Z-1488-CPR-0810/W, page 4/4
which is an integral part of the certificate No. 1488-CPR-0810/W

External, hinged, fire resisting or fire resisting and smoke control doors of ALUPROF® MB-78EI system with over panels and/or side panels

General identification of the product ¹⁾:

Table No. 3. Doors of the ALUPROF® MB-78EI system - version **MB-78EI EI90** - optionally equipped with over panels and/or side panels - within one common structural frame.

Declared essential characteristics, acc. to PN-EN 16034:2014-11	Resistance to fire	Resistance to fire Smoke control	Resistance to fire Smoke control Self-closing	Resistance to fire Self-closing	
Classification acc. to PN-EN 13501-2:2016-07	EI ₂ 90/ EW 90/ E 90	EI ₂ 90/ EW 90/ E 90/ S _a , S ₂₀₀	EI ₂ 90/ EW 90/ E 90/ S _a , S ₂₀₀ / C5	EI ₂ 90/ EW 90/ E 90/ C5	
Construction features	Aluminium, profile, single- and double-leaf, hinged doors, with transparent and/or opaque infills of door leaves as well as side and over panels; profiles of leaf and frame - aluminium profiles of the MB-78EI system with a thermal barrier; depth of structural profiles - 78 mm				
	Construction details, as described in points: 3.2, 3.7, 3.8 of classification report No. 1036.6/20/R499NZP, ed. 3	Construction details, as described in points: 4.2, 4.7, 4.8 of classification report No. 1036.6/20/R499NZP, ed. 3	Construction details, as described in points: 5.2, 5.7, 5.8 of classification report No. 1036.6/20/R499NZP, ed. 3	Construction details, as described in points: 6.2, 6.7, 6.8 of classification report No. 1036.6/20/R499NZP, ed. 3	
Transparent infills ²⁾	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber insulating glass units, as described in point 3.3 of classification report No. 1036.6/20/R499NZP, ed. 3	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber insulating glass units, as described in point 4.3 of classification report No. 1036.6/20/R499NZP, ed. 3	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber insulating glass units, as described in point 5.3 of classification report No. 1036.6/20/R499NZP, ed. 3	Applies to: door leaves and side- and over panels. Single glass panes or single-chamber insulating glass units, as described in point 6.3 of classification report No. 1036.6/20/R499NZP, ed. 3	
Opaque infills ²⁾	Applies to: door leaves and side- and over panels. Opaque infills according to the description in points: 3.4, 3.5 of classification report No. 1036.6/20/R499NZP, ed. 3	Applies to: door leaves and side- and over panels. Opaque infills according to the description in points: 4.4, 4.5 of classification report No. 1036.6/20/R499NZP, ed. 3	Applies to: door leaves and side- and over panels. Opaque infills according to the description in points: 5.4, 5.5 of classification report No. 1036.6/20/R499NZP, ed. 3	Applies to: door leaves and side- and over panels. Opaque infills according to the description in points: 6.4, 6.5 of classification report No. 1036.6/20/R499NZP, ed. 3	
Fittings	Assortment of fittings, as described in point 3.6 of classification report No. 1036.6/20/R499NZP, ed. 3				
Dimensions ³⁾	External dimensions of a door leaf (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm]	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1400) x (392 ÷ 2500)	(392 ÷ 1400) x (392 ÷ 2500)
	Max. total width of two leaves of double-leaf door, [mm]	2784	2500	2500	2784
	Maximum door height including over panel, [mm]	3436	3225	3225	3436
	Max. external dim. of the over panels (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm] - in relations to their permissible surface area [m ²]	(372 ÷ 2610) x (372 ÷ 936) 0,14 ÷ 2,42 or (372 ÷ 2584) x (372 ÷ 1125) 0,14 ÷ 2,91	(372 ÷ 2384) x (372 ÷ 936) 0,14 ÷ 2,23 or (372 ÷ 2584) x (372 ÷ 765) 0,14 ÷ 1,98	(372 ÷ 2384) x (372 ÷ 936) 0,14 ÷ 2,23 or (372 ÷ 2584) x (372 ÷ 765) 0,14 ÷ 1,98	(372 ÷ 2610) x (372 ÷ 936) 0,14 ÷ 2,42 or (372 ÷ 2584) x (372 ÷ 1125) 0,14 ÷ 2,91
	Max. external dimensions of the side panels (W _{min} ÷ W _{max}) x (H _{min} ÷ H _{max}), [mm] - in relations to their permissible surface area, [m ²]	(372 ÷ 1100) x (372 ÷ 2550) 0,14 ÷ 2,80	(372 ÷ 1100) x (372 ÷ 2300) 0,14 ÷ 2,53 or (372 ÷ 681) x (372 ÷ 2550) 0,14 ÷ 1,74	(372 ÷ 1100) x (372 ÷ 2300) 0,14 ÷ 2,53 or (372 ÷ 681) x (372 ÷ 2550) 0,14 ÷ 1,74	(372 ÷ 1100) x (372 ÷ 2550) 0,14 ÷ 2,80
	Permissible leaf surface area of single-leaf door [m ²]	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50
	Permissible leaf surface area for double-leaf doors, [m ²]	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50	0,15 ÷ 3,50

¹⁾ The detailed technical identification, scope and conditions of use of the doors ALUPROF® MB-78EI system – version MB-78EI EI90 covered by this certificate No. 1488-CPR-0810/W, are included in the classification report No.: 1036.6/20/R499NZP, ed. 3

²⁾ The selection of transparent and opaque infills should take into account the requirements of national regulations in individual EU member countries regarding the levels of performance related to the essential characteristics covered by EN 14351-1:2006+A2:2016 (among others, this applies to the heat transfer coefficient), which are not covered by the scope of tasks of the notified certification body and this certificate.

³⁾ When selecting dimensions, the requirements of national regulations in individual EU member countries should be taken into account.

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 27.07.2023



INSTYTUT TECHNIKI BUDOWLANEJ
CERTIFICATION DEPARTMENT

ul. FILTROWA 1, 00-611 WARSZAWA
tel.: +48 (22) 57 96 167, +48 (22) 57 96 168
e-mail: certyfikacja@itb.pl, www.itb.pl

CERTIFICATION MARK

The company:

Przedsiębiorstwo Produkcyjno - Usługowe PLASTIMET Sp. z o.o.
ul. Suwalska 82
19-300 Ełk
Poland

being the manufacturer of the products:

External, hinged, fire resisting or fire resisting and smoke control doors of ALUPROF® MB-78EI system with over panels and/or side panels

is authorized to use
the ITB certification mark „WYRÓB BUDOWLANY”
during the period of validity of the certificate no. 1488-CPR-0810/W



1488-CPR-0810/W

HEAD
of the Certification Department

Katarzyna Hatowska, M.Sc. Eng.



DEPUTY DIRECTOR
of Instytut Techniki Budowlanej

Anna Panek, M.Sc. Eng.

Warsaw, 27.07.2023